



TOWN OF KILMARNOCK

Council Committee Report –Water/Wastewater

Date: July 2, 2015 Time: 10:00 AM Location: Town Hall

Town Council Member Attendees:

X = present

Chair: Council Member Michael Sutherland _X_
Council Member Keith Butler __
Vice Mayor Rebecca Nunn _X_
Council Member Dr. Curtis H. Smith _X_
Mayor Mae Umphlett (ex-officio) __

Town Staff Attendees:

Town Manager Tom Saunders _X_
Susan Cockrell, Deputy Town Mgr. _X_
P.J. Jones, Supervisor, Public Works _X_
Wayne Kent, Utilities _X_
Marshall Sebra, Planning & Zoning Director _X_

Visitors: None

Discussion items:

1. Staff reports: PJ Jones: Repairs to the grit pump gearing and the aeration blower motor are underway. The grit pump spider gear has been replaced and a replacement motor is due in by mid-month; Wayne Kent: All lift stations are operating normally and sidewalk repairs have facilitated installing additional radio read meters as replacements for existing meters.
2. DEQ now considers our Consent Order to be completed.
3. Three rounds of testing of Northern Neck Brewing’s waste stream have been completed at the WWTP. A 4th round of the maximum batch size is targeted next. Impact on BOD’s is being evaluated.
4. Council is requested to provide input to the FY 2016 WWTP/Utilities goals and “To Do” list for next month’s committee meeting.
5. The discussions on easements for sewer connections\access on S. Main block between Augusta St. and Irvington Rd. are nearly complete. Once completed, engineering work will begin.

FYI:

1. FOG inspection processes continue weekly.
2. 2014 Consumer Confidence Report posted to website (6\15), on water bills (6\15 cycle) and in Rappahannock Record (6\25\15).

Recommendations to Council: None

Recommended for further study: None